

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

Table of Contents

	Page
CHAPTER 1	3
Purpose of Service Rules	
Code Compliance and Inspection	
Service Entrance Equipment	
Application for Service	
Increased Loads	
Continuity and Quality of Service	
Neutral Voltages	
Resale of Energy	
CHAPTER 2 TYPES OF SERVICE AND VOLTAGES AVAILABLE	8
Types of Service and Nominal Voltage Furnished	
CHAPTER 3 LINE EXTENSIONS	9
Line Extensions on Private Property	
Line Extensions of Other Than Private Property	
Overhead Conductor Clearances	
CHAPTER 4 SERVICES	10
Service Location	
Overhead Service	
Underground Service	
Temporary Service	
Relocation of Service	
CHAPTER 5 COMPANY EQUIPMENT ON MEMBER'S PREMISES	15
Sealing of Equipment	
Theft of Service	
Transformers – Single or 3 phase	
CHAPTER 6 METERS	16
Single Meter and Service Rule	
Wiring for Meters	
Meter Locations	
Metering Pedestals, Single Phase, Underground Service	
Meter Sockets	
Current Transformer and URD Service Termination Cabinet	
Single-phase Service 200 Amperes or less	
Single-phase Service 201 to 400 Amperes	
3 phase, 3 or 4 wire Delta or Wye Services, 200 Amperes or less	
3 phase, 4 wire Delta or Wye Services above 200 Amperes	
Padmount Current Transformer Metering	
Grounding of Current Transformer Cabinets and Instrument	
Transformer-rated Meter Sockets and Cabinets	
Grounding at Metering Installations and Service Entrances	

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

CHAPTER 7 MOTORS AND MOTOR REGULATIONS	21
3 phase Motors	
CHAPTER 8 WATER HEATING	22
Continuous Service Water Heating	
Storage Type Space Heating and Cooling	
CHAPTER 9 ELECTRIC SPACE HEATING	23
CHAPTER 10 RECTIFYING TYPE CONTROLS	23
CHAPTER 11 ELECTRIC WELDERS AND FURNACES	23
CHAPTER 12 CUSTOMER GENERATING EQUIPMENT	24
Standby Generating Equipment	
Parallel Generation System	
CHAPTER 13 MOBILE HOMES & MODULAR HOMES	25
Single Meter Installation	
Grouped Meter Installation	
CHAPTER 14 LOAD MANAGEMENT & REBATE PROGRAMS	26
Water Heater Program	
Geothermal Heat Pump Program-Dual Fuel	
Air Source Heat Pump Program-Dual Fuel	
Plenum Heater	
Electric Thermal Storage Program	
Electric Boiler Program	
Central Air Conditioning Program	
Load Management Receiver Wiring Guide	
APPROVED EQUIPMENT LIST	30
DRAWINGS & SPECIFICATIONS	
Overhead on building – 200 amps or less	32
Overhead – 200 amps or less	34
Underground on building – 200 amps	36
Underground on building – 200 amps w/ main breaker	38
Overhead - Mobile Home	40
Underground - Mobile Home	42
Underground - Mobile Home (free standing)	44
Overhead, 400 amp, Single Phase	46
Underground, 400 amp, Single Phase	48
Underground, 400 amps +, Three Phase	50

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 1 – General

Purpose of Service Rules

The following information, detailing the rules and regulations of the Cooperative concerning electric service installations, is published for the convenience of the Cooperative's members and their architects and contractors. These rules are in addition to the Wisconsin Administrative Code, the National Electrical Code, and any other regulations that may apply. The Cooperative reserves the right to make revisions in these rules whenever changes in the article, legal requirements, or other circumstances make it advisable. These rules are intended for standard equipment installations. When, because of physical limitations of the premises, it is impractical to follow them, the Cooperative shall be consulted for permissible modifications. The information contained herein does not specifically cover the requirements of the Cooperative's rate schedules, line extension policy, or general rules; the Cooperative should be consulted for information concerning these matters.

The Cooperative may refuse or discontinue service if a member does not comply with these rules; however, the member will first be notified and afforded reasonable opportunity to comply. Service may be discontinued without prior notice when dangerous conditions exist on the member's premises.

Member Wiring – Code Compliance and Inspection

All wiring shall be done in accordance with requirements of the Wisconsin Administrative (electrical) Code, the National Electrical Code, the Cooperative's rules and other local requirements which may apply.

The Cooperative will not inspect member's wiring or equipment beyond the metering pedestal or cabinet for compliance with the applicable codes.

In new wiring installations or when changes in existing wiring are made which require the removal of meters or the disconnection of service, the Cooperative shall not connect or resume service until the contractor or person doing the wiring furnishes the Cooperative with a wiring affidavit showing proof of compliance with the Wisconsin Administrative (electrical) Code and the National Electrical Code.

Inactive accounts where the meter and service have been removed shall be treated as new wiring when a request for service is received. (See above paragraphs.)

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

The Cooperative will not interpret the electrical code. Questions concerning code interpretations should be referred to the local or state electrical inspector. The address and phone number is:

State of Wisconsin/DILHR
Industrial Safety & Building Division
201 East Washington Avenue
PO Box 7969
Madison, WI 53707
Phone: (608) 266-3064

The Cooperative will inspect for compliance with its rules and may refuse or discontinue electric service if its rules are not complied with or if a hazardous condition exists.

Service may be obtained prior to completion of wiring if the service entrance is completed and compliance with Cooperative rules and proof of compliance with applicable codes has been received.

Cooperative crews setting meters or connecting new services for single-phase one-family dwellings test for infinite resistance at the meter socket load terminals. If this check indicates connected load at the load terminals, the meter will not be set. It is recommended that the service disconnect switch be left open to avoid the indication of connected load at the meter base. *COOPERATIVE CREWS WILL NOT ENTER A BUILDING TO OPEN OR INSPECT THE SERVICE DISCONNECT SWITCH.*

Service Entrance Equipment

- A. The member shall own, install, and maintain the service entrance equipment.
- B. Single-phase service for one and two-family dwellings, 200 Amperes or less, shall have fuses or breakers installed as part of the service entrance equipment rated a minimum of 10,000 Amperes interrupting capacity. On all other service, consult the Cooperative for maximum available short circuit current.
- C. Insulated neutral or grounded conductors of a service entrance shall be identified by a white or natural gray color. Four-wire 120/240 volt Delta installations shall have the conductor with the higher voltage to ground identified with orange over its entire length or shall be identified with orange paint or tape at any point where a connection is to be made.
- D. Member owned lightning arresters or other surge protection devices, if used, shall be installed on the load side of the customer's service overcurrent protective devices. Unless, specific approval has been received from the Cooperative to install them ahead of the overcurrent protective devices.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Application for Service

Guidelines for applying for service are outlined below.

- A. **Application for Initial Service**
Application for initial service or for a change in existing service
Information needed by the member in order to proceed with the installation
can be obtained from OEC's office.

- B. **Site Visit**
A site visit is necessary to determine the location of the temporary and/or
permanent service termination point.

- C. **Construction Charges**
The Staking Engineer will calculate the construction charges at the site
visit. All charges must be paid prior to the installation of the service.

- D. **Member's Underground Facilities**
Member will be required to fill out and sign an Underground Service
Agreement. This form is available at OEC's office. (This form shows any
private facilities buried that might be in conflict with the proposed new
underground service path.)

- E. **Easements and Government Requirements**
Easements required from the applicant and from other parties shall be
obtained by the applicant at no cost to the Cooperative. The Cooperative
may prepare the easements for the applicant's signature. Any permits,
inspections, surveys, etc, required before construction which require a fee,
shall be paid for by the party requesting service.

- F. **Line Clearance (Tree & Brush Removal)**
Applicant is responsible for initial clearing of right-of way on applicant's
property as required for line construction.

- G. **Completion of Service Entrance Wiring**
The electrician shall provide notification to the Cooperative of compliance
with local and/or state electrical codes before a service will be connected.
This will be in the form of an affidavit furnished by Oconto Electric
Cooperative and completed by the contractor or person doing the wiring.

- H. **Job Scheduling**
Prior to job scheduling by the Cooperative, the following items, where
applicable, are required:
 - All paperwork and fees have been submitted
 - Cable route has been cleared of any brush, dirt piles, and debris
 - Electric meter base has been installed and an affidavit has been
submitted to OEC

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

- Electric meter base has been inspected and called in to OEC
- The foundation wall is backfilled to within 6" of final grade

Increased Loads

In cases where member's load requirements have changed, necessitating a larger meter or transformer, the Cooperative shall be given reasonable notice so that it may provide a meter, service drop, and transformer of the proper capacity. Delays, poor service or a burned-out meter or transformer will thus be avoided. This applies particularly to members who connect temporary or portable equipment. The Cooperative may charge for the replacement cost of damaged Cooperative equipment.

Continuity and Quality Service

The Cooperative will use reasonable care to provide an uninterrupted and regular supply of service; but shall not be liable for any loss, injury, or damage resulting from interruptions, deficiencies or imperfections of service not due to willful default or negligence on its' part.

The Cooperative shall have the right to cause service to any customer to be interrupted or limited at any time, without liability, by automatic devices or otherwise, when in the judgment of the Cooperative such interruption or limitation is necessary or desirable due to emergency conditions.

All motors, appliances or equipment connected to the Cooperative's system shall be so designed, installed, and operated as not to cause interference to other Members' service equipment nor to impede the Cooperative in maintaining proper system conditions.

It shall be the responsibility of the member to provide motor protection for undervoltage, overcurrent, short circuit, and loss of a phase reversal.

The Cooperative may also curtail or temporarily interrupt the member's electric service in order to make repairs, replacements or changes to the Cooperative's facilities, either on or off the member's premises. The Cooperative will, whenever practical, give notice to members who might be seriously affected by such suspension or curtailment of service.

It is intended that the voltage provided to the member comply with the requirements of the Wisconsin Administrative Code. This code allows voltage transients of an infrequent nature, which may adversely affect the operation of certain sensitive equipment. Prevention of undesirable operation of sensitive equipment caused by these transients is the responsibility of the member.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Neutral Voltages

It is normal for the Cooperative's system neutral to carry low voltage levels, particularly in rural areas. This voltage creates no difficulty for most members. Where a problem is experienced due to this voltage, measures are available to the member to eliminate the problem. Proper grounding of wiring, bonding, and other electrical connections on the member's premise by the member and his electrician are important factors in mitigating such problems.

Resale of Energy

Service shall be for the member's use only and may not be sold, remetered or otherwise disposed of by the member to lessee, tenants or others, except with the consent of the Cooperative in accordance with the Cooperative's appropriate Rate Schedule permitting such use of service. This does not prohibit the installation of test or check meters for informational purposes.

Including the cost of electric service in the rent without identification as such is permitted.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

Chapter 2 - Types of Service and Voltages Available

For other than one- or two-family dwellings, the Cooperative shall be consulted as to the type of service available in any area before wiring layouts are made, equipment is purchased, or when extensive wiring changes are contemplated.

The Cooperative furnishes 60-Hertz (cycles) alternating current, single- and three-phase, at various voltages, but not all types of service are available in every locality.

The type of service available to the member is ordinarily determined by one or more of the following conditions:

1. Types of service available at the member's location.
2. Character and size of load to be served.
3. Temporary or permanent.
4. Underground or overhead service.

The Types of Service and Nominal Voltage Furnished

1. Single-phase, 120/240 volts, three-wire. Maximum 400 Amp (100 KVA)
2. Three-phase, 480 volts, three-wire. (Limited availability; consult Cooperative.)
3. Combination single-phase and three-phase, 120/240 volts; four wire Delta. (New members limited availability; consult Cooperative.)
4. Combination single-phase and three-phase, 120/240 volts, four-wire Wye.
5. Combination single-phase and three-phase, 277/480 volts, four-wire Wye.

Electric service at other voltages and capacities may be obtained under special circumstances.

Members' request for additional services or services which do not conform to these rules shall be treated as "special facilities". The member is obligated, in accordance with Cooperative extension rules, for any added cost involved. The Cooperative reserves the right to deny special facilities.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 3 – Line Extensions

Line Extensions on Private Property

Extensions of the Cooperative's distribution lines on to property of the member to be served will be made in accordance with the Cooperative's extension rules which are available at the Cooperative office. These rules provide, among other things, that the Cooperative will own and be responsible for the maintenance and operation of such lines and shall have the right of access at all reasonable times for construction, reconstruction, tree trimming, maintenance inspection, rebuilding, maintenance and operation of lines and equipment with the right to remove poles and other equipment upon discontinuance of service. The Cooperative shall also be granted the right to extend its facilities to serve other members from such lines.

Oconto Electric Cooperative will prepare all necessary easements along the route selected. The member requesting service shall be responsible for obtaining all signatures and all associated easement costs. Permanent survey stakes identifying property lines may be required by the Cooperative prior to installation of facilities.

When installed at member request, the member shall grant rights-of-way satisfactory to the Cooperative for the installation and maintenance of the electric facilities. The right-of-way as designated by the Cooperative shall be cleared of trees and other obstructions by or at the expense of the member.

The member shall provide grading within six inches of finished grade for the area covered by the right-of-way so that the underground facilities can be properly installed in relation to the finished grade.

Line Extensions on Other Than Private Property

The Cooperative shall obtain all licenses or permits that are necessary for right-of-way along the route which are not on private right-of-way. Examples are highway permits, railroad licenses, etc. Associated permit and license fees are the obligation of the member applying for service.

Overhead Conductor Clearances

Contact Oconto Electric Cooperative prior to construction near or beneath overhead wires.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 4 - Services

The Cooperative will extend service to members as promptly as practical consistent with prevailing conditions and will cooperate with contractors and members at all times in order to provide proper service connections. It is requested that application for service be made as early as possible in order to permit the Cooperative to schedule its work. Where there is a question concerning the meaning or application of the Cooperative rules, unnecessary delays or expense may be avoided by consulting the Cooperative in advance of construction. Members, their architects, engineers or contractors shall consult the Cooperative concerning entrance and meter locations; service voltage; the type, phase and voltage of motors and other equipment. They shall consult the Cooperative concerning the installation of special circuits for separate metering or control to meet the rate requirements of the Cooperative and permit adequate service.

Service Location

The location of the member's service entrance shall in all cases be designated by the Cooperative. The Cooperative or its representatives shall make all connections to its lines, and in no case shall these connections be made by other than Cooperative representatives. To avoid misunderstanding and additional expense, the Cooperative shall be consulted concerning all new service connections.

Disconnecting means shall be provided to disconnect the utility wiring from the premises wiring at any point where utility wiring terminates and premises wiring extends overhead or underground to one or more buildings or structures.

Raceways containing unmetered conductors shall not be concealed.

Overhead Service

A. Conductor Clearances

In selecting the location of the point of attachment of the service drop, the Cooperative will give careful consideration to code clearance requirements, location of its supply lines, the needs of the member and the property of others. Overhead service drops from the pole to the member's point of attachment shall not be greater than 150 feet in length.

The member's service entrance shall be located so that the Cooperative service wires will not be interfered with by trees and so that buildings and other obstructions are cleared vertically and horizontally in accordance with requirements of the State Electrical Code.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Conductors shall have a clearance of not less than 8 feet from the highest point of roofs over which they pass except as follows:

1. This clearance may be reduced to 3 feet for supply conductors limited to 300 volts to ground and communications conductors and cables if the roof has a slope of not less than 1 to 3.
2. Where a roof has a pitch of 1 to 3, service drop conductors of 300 volts or less, which do not pass over other than a maximum of 4 feet of the overhang portion of the roof for the purpose of terminating at a through roof service raceway or approved support may be maintained at a minimum of 18 inches from any portion of the roof over which they pass.

Overhead service or line conductors:

1. Should not pass over swimming pools or the surrounding land within 10 feet from the outside edge of the pool. Consult the Cooperative when it is necessary for service or line conductors to pass over this area.
2. Shall not pass over areas where material is regularly stored and handled by cranes or other types of high machinery unless the clearance of the service drop is adequate to permit full use of the equipment.
3. Shall not pass over above-ground storage tanks (LP gas tanks over 1000 gallon) and the area extending 8 feet horizontally from the tank if the voltage is 300 volts to ground or less, 15 feet horizontally if above 300 volts to ground.
4. Shall not pass over wells within a horizontal distance of not less than $\frac{3}{4}$ of the required vertical clearance.

B. Service Conductor Termination

The Cooperative will provide and the member or contractor shall install the attachment device. The attachment device shall be installed in a location suitable to permit compliance with clearance requirements and of sufficient strength to support the service drop conductors.

In all cases the member shall be required to extend his service entrance to a sufficient height, not ordinarily exceeding 30 feet, to meet all of the minimum ground clearance requirements for overhead service installation.

If the service attachment on the building cannot be placed at a sufficient height to permit the Cooperative to meet Code ground or other clearance requirements, the member shall provide a support of suitable strength and height to which the service wires can be attached in order to meet the clearance requirements. All such supports shall be durable and of weather resisting material.

Disconnection means shall be provided to disconnect the utility wiring from the premises wiring at any point where the utility wiring terminates and premises wiring extends overhead or underground to one or more

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

buildings or structures. All underground premises wiring shall also have overcurrent protection in accordance with the ampacity of the underground conductor.

If the support is a pole, it shall have a minimum top diameter of 5 inches, treated with an approved preservative a minimum of 6 inches above and 18 inches below the ground line. The pole shall be set a minimum of 5 feet in the ground and guyed.

The member's service entrance weatherhead shall be installed 6 inches above the designated point of service attachment.

Service entrance conductors shall project at least 30 inches beyond the service head to permit the proper connections to the service wires. The neutral or grounded entrance conductor shall be permanently identified.

Underground Service

The Cooperative will install and maintain Cooperative-owned underground electric facilities. Their location, the meter location, and service termination shall be specified by the Cooperative. Underground Extension Rules are available at the Cooperative office.

A. Member Requirements

The member shall identify all privately owned underground equipment on a form provided by Oconto Electric Cooperative prior to the installation of Cooperative underground electric facilities. Damage to member-owned underground equipment not located and/or identified by the member shall be the member's responsibility.

The member shall grant rights-of-way satisfactory to the Cooperative for the installation and maintenance of the underground electric facilities.

The member shall provide the following at no expense to the Cooperative:

1. The rights-of way shall be cleared of trees and other obstructions.
2. Grade within 6" of finished grade of the area covered by the right-of-way so that the underground facilities can be properly installed in relation to the finished grade.
3. Space for underground service conduit riser and conductors shall be clear of obstructions extending a minimum of 30" below grade.
4. Conductors located beneath buildings, pavement, or other obstructions shall be placed in conduit extending 3 feet beyond the obstruction. If obstructions are placed on the service right-of-way after the service is installed, additional repair costs incurred due to the obstruction will be billed to the member if repairs to the service become needed.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

- B. Underground Conductor Clearances
Underground conductors shall not be installed:
1. Within 5 feet of the inside walls of swimming pools.
 2. Within 20 feet of fuel storage tanks unless inside of duct supplied or approved by the Cooperative, the duct to be provided at member's expense. The duct shall be a continuous piece without splice and shall be of sufficient length to protect the cable for a minimum of 20 feet beyond either side of the fuel tank.
 3. Within 10 feet of septic fields, including backup septic field area.
 4. With 25 feet of the mound system. The underground conductor cannot be installed between the tank and the mound because the line between these two is pressurized. Construction equipment shall not travel in the area within 25 feet of the mound system.
Note: The clearance along the sides and the top side could be less. Check with the local county for their requirements.
 5. Within one foot of private sewer lines.
 6. Under areas designated as Class I hazardous locations. (These are areas such as gasoline dispensing stations.)
 7. Within five feet of well curbing or casing.

- C. Terminating Underground Service Conductors
Underground service conductors shall terminate at the metering point.

Disconnecting means shall be provided to disconnect the utility wiring from the premises wiring at any point where the utility wiring terminates and premises wiring extends overhead or underground to one or more buildings or structures. All underground premises wiring shall also have overcurrent protection in accordance with the ampacity of the underground conductor.

1. Single-phase or three-phase service, one meter, 200 Amperes or less shall terminate at the meter socket line terminals.
2. For single-phase or three-phase multiple socket installations, the member shall provide a single point of termination for Cooperative underground service conductors.
3. Current transformer metering on services larger than 200 Amp will be installed in, and underground service conductors terminated in a pre-bussed enclosure approved by the Cooperative and owned, installed, and maintained by the member. The Cooperative shall be consulted for conduit or pedestal location and installation specifications.
4. Conduit risers shall have a sleeve placed around the conduit where the conduit passes through a concrete slab.
5. Soil or ground water conditions generally require the installation of above ground entry of underground service conductors to prevent seepage or water entering through the entrance conduit. The Cooperative will not be responsible for any damage caused by water seeping into the buildings through the member's raceway or conduit.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

6. Ground rods and the grounding conductor shall not be installed within 2 feet of the underground cable route. The grounding shall not be installed in the conduit or pedestal with underground service entrance conductors.

Temporary Service

Temporary service structures shall be adequately supported and of a sufficient height to permit compliance with required Code clearances. The structure, including bracing, shall be clear of the underground service trench route by a minimum of four feet. Installation and removal costs of single-phase temporary services to 200 Amperes is covered by a single, fixed-fee which applies in most service installations. The temporary should be located as close as practical to an existing overhead transformer pole, or within 6 feet of a padmount transformer.

Relocation of Services

Any change requested by a member in the point of service termination or removal and reinstallation of service conductors will be billed to the member.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

CHAPTER 5 - Company Equipment on Member's Premises

The Cooperative shall have the right to install, inspect and maintain its equipment on the member's premises as is necessary to furnish proper service. All such equipment shall remain Cooperative property, and the Cooperative shall have the right to remove it on discontinuance of service. The member shall be responsible for damages and losses resulting from interference or tampering with such equipment caused or permitted by the member. In the event that the Cooperative equipment is interfered with or damaged, the Cooperative may require the member to change his wiring, at his own expense, to permit the installation of other Cooperative equipment or to permit the relocation of Cooperative equipment to avoid further interference or damage.

Sealing of Equipment

Meters and all associated metering equipment, service termination boxes, wire raceway, and service entrance switches containing unmetered conductors are sealed by the Cooperative. This equipment must be designed with provisions for seals or locks as specified by the Cooperative. The Cooperative may grant permission to remove a meter seal for maintenance of member equipment or fuse replacement. The Cooperative must be notified of any seal removal no later than the following working day.

Unauthorized removing of Cooperative seals is unlawful and may result in a billing for the investigation and replacement of the seal as well as criminal prosecution.

Theft of Service

The Cooperative will investigate for the possibility of theft of service whenever tampering with meter seals, meters, service conductors, and service connections is reported or detected. Only Cooperative authorized persons are permitted to make connections to Cooperative lines.

If the investigation determines that electricity is being stolen, the service may be disconnected.

Prior to restoration of service the member's service entrance equipment shall be made tamper resistant in accordance with Cooperative requirements and satisfactory arrangements will have been made for payment of the estimated amount of unmetered electricity.

Theft of service may result in criminal prosecution.

Transformers – Single or Three Phase

For Cooperative-owned transformer ground settings or padmount transformers, the member shall provide according to Cooperative specification the necessary space, grading, fill, crushed stone, equipment, any formed structured foundations or formed transformer pad, protective barriers and window barriers at no cost to the Cooperative. The Cooperative shall furnish the enclosing fence if required and any preformed transformer pads.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 6 - Meters

Single Meter and Service Rules

The Cooperative will normally supply to each member's building structure or premises:

1. One service lateral (drop)
2. One class of service
3. One meter

Exceptions to this rule are:

1. Multiple occupancy buildings which comply with the Wisconsin State Electrical Code by having areas under different occupancies separated by approved firewalls may be supplied by more than one service.
2. Fire pumps or other emergency electrical systems requiring separate service.
3. Where more than one point of delivery or more than one point of metering is necessary because of interruptible service rate, governmental requirements or regulatory rules.

Wiring for Meters

The Cooperative will under no circumstances permit "Jumpers" to be placed in meter sockets, which results in unbilled energy.

Metered and unmetered conductors shall not be installed in the same conduit or raceway.

On group installations each service switch, breaker, meter pedestal socket or cabinet shall bear a distinctive, permanent marking clearly identifying the location to be served. The location being served shall be identified in the same manner.

The Cooperative shall not permit meters or instruments other than its own to be connected to its meter wiring.

Meter Locations

Members shall provide a suitable location for meters and associated equipment determined by and without charge to the Cooperative.

Meters shall be installed in an accessible location to enable them to be safely read, inspected and tested at reasonable times with a minimum of inconvenience to the member and Cooperative.

Multiple meter installations served from a single entrance shall be grouped at a location approved by the Cooperative.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

All single-phase and polyphase meter installations shall be located out of doors.

Meters shall not be installed in patio, porch, deck or carport areas or areas likely to be enclosed.

At earth bermed buildings that do not have an exposed side suitable for the meter location, the service shall be terminated at a meter pedestal.

Meters shall not be installed on mobile homes. (Please see Chapter 13)

The meter location shall be on a solid structure free from vibration and possible mechanical damage.

The member shall be responsible for providing protection for the meter(s) from damage caused by falling ice, snow or other objects. In locations where the meter is not protected by roof overhang, the member shall provide a protective shield.

The clear working space in front of meter panels shall be a minimum of 4 feet and a vertical clearance of 6 feet 6 inches. Two feet of horizontal clearance on either side shall also be provided. Free space in front of instrument transformer cabinets shall be 2 feet beyond the cover in the extended position or a minimum of 4 feet whichever is greater.

If changes are made on the member's premises making the existing meter location unsafe or inaccessible for reading and testing, the member shall be required to make changes in the wiring so that the meter may be located to comply with these rules. Failure of the member to correct his wiring within a reasonable length of time after written notification shall be considered as noncompliance with these rules. The Cooperative reserves the right to discontinue electric service until the member has changed his wiring as outlined above.

Metering Pedestals - Single-Phase, Underground Service

Meter pedestals shall be furnished, installed and maintained by the member.

Pedestal style meter sockets shall be required for outdoor locations through 200 Amperes. This includes up to four-meter positions. Minimum rating of 200 Amperes is required.

Metering pedestals shall be adequately supported to maintain the meter socket in a level and plumb position.

On group installations each meter socket and service switch shall be permanently marked identifying the location to be served. The location being served shall be identified in the same manner.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Metering pedestals shall meet Cooperative and applicable Code requirements.

Meter Sockets

Meter sockets shall be furnished, installed and maintained by the member.

Meter sockets shall be installed in a level and plumb position securely attached to a solid backing.

Single-phase meter sockets larger than 200 Amperes shall be equipped with a manual bypass so designed that a visual check of the bypass connections can be made with the meter in its installed position. The bypass shall be so designed that when in operation, the socket cover cannot be closed.

Meter sockets shall have connectors suitable for aluminum or copper conductors.

Corrosion inhibitor shall be used on all connections to aluminum conductors.

Single-phase and three-phase meter sockets shall be installed so that the top of the meter shall be not more than 5 feet 6 inches or less than 4 feet 0 inches above finish grade for overhead services and not more than 5 feet 6 inches or less than 3 feet 0 inches for underground services.

On group installations the meter sockets shall be the following:

1. Indoor – Bottom meter shall maintain a minimum of 2 feet above the floor.
2. Outdoor – Bottom meter shall maintain a minimum of 3 feet above the ground. Top meter shall maintain a maximum of 6 feet above the ground.

(All measurements are made from the floor/final grade to the top of the electric meter.) Group or ganged sockets shall have a single point of termination for Cooperative conductors.

Meter sockets shall have a minimum of 4 inches clearance on all sides of the meter socket.

Self-contained polyphase sockets shall have the following provisions:

1. 200 Ampere minimum rating, single position.
2. The following minimum dimensions for underground service:
Height – 16 inches, Width – 12 ½ inches, Depth – 4 ½ inches
3. Clamp type jaws
4. 600 volts minimum rating
5. Manual bypass (not horn type)
6. Wrench operated connector tightening device
7. Protective shield covering the jaws to prevent accidental shorting or grounding.

Contact the Cooperative office for transformer-rated sockets used on polyphase services. Duplex sockets are required unless otherwise specified by the Cooperative.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Current Transformer and Underground Service Termination Cabinet

The member shall furnish and install all current transformer cabinets and underground service termination cabinets.

All cabinets shall be prebussed enclosures approved by the Cooperative. (Please see "Approved Equipment List")

All cabinets shall be so installed that the top of the cabinet is not more than 90 inches or the bottom not less than 12 inches above permanent grade or platform.

Single-Phase Service 200 Amperes or Less

Meters shall be located out of doors.

Single-Phase Service 201 to 400 Amperes

Commercial and farm 400 Ampere services shall use a prebussed current transformer cabinet approved by the Cooperative and shall be located out of doors.

Three-Phase, Three and Four-Wire Delta or Wye Services 200 Amperes or Less

Meters shall be socket type and located out of doors. Contact the Cooperative office for installation specifications.

Three-Phase, Four-Wire Delta or Wye Services Above 200 Amperes

On new installations or existing installations of these types that are to be rearranged, the Cooperative shall be consulted for installation specifications.

Meter sockets, current transformer cabinets, and underground service termination cabinets shall be furnished and installed by the member.

Padmount Current Transformer Metering

Current transformers may be installed in padmount transformers when the following guidelines are met:

1. Padmount current transformer metering shall have approval of the Cooperative Operations Department.
2. The padmount transformer shall be located on the property of the member being served and should serve only that member.
3. The member shall own, install and maintain the service.
4. The Cooperative will specify the service conductor size (not ampacity) and will provide and install the lugs for terminating the member's conductors at the padmount end.
5. If a suitable wall for mounting the meters is not available within 25' of the padmount transformer, a structure of adequate strength for mounting meters shall be provided by the member. Two 4" X 4" I beams or 3" heavy-walled pipe 10' long with 4 1/2' buried in 8" diameter concrete supports will meet minimum requirements. An alternate support would be two 5 1/2" X 5 1/2" X 10' treated wood posts. A PVC schedule 80 conduit, 1 1/4" minimum, shall be provided and installed by the member from the meter socket to the secondary opening in the pad.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

6. Location of padmount, meter, and conduit will be specified by the Cooperative.

Grounding of Current Transformer Cabinets and Instrument Transformer-Rated Meter Sockets and Cabinets

Grounding Methods for Current Transformer Cabinets

1. For services with grounded circuit conductor (all 4-wire and 3-wire, 240 volt services) a bonding jumper shall be connected to the grounded phase or neutral conductor and the metal cabinet frame.
2. Services without grounded circuit conductor (3-wire, 480 volt) shall have:
 - a. Bonded metallic service conduit between the service entrance switch and the cabinet.
 - b. A bonding conductor from the service entrance switch ground of ampacity equal to the service entrance conductors, to the cabinet.
 - c. Two driven electrodes with grounding electrode conductor to meet National Electric Code and Wisconsin Administrative Code.

Grounding Methods for Transformer-rated Meter Sockets and Cabinets

1. Bonded metallic conduit between the meter socket or cabinet and the transformer cabinet.
2. A #8 bonding conductor from the service entrance switch or transformer cabinet equipment ground.
3. For pole metering, a #6 bonding conductor connected to the pole ground wire.

Grounding at Metering Installations and Service Entrances

The grounding electrode conductors from the ground rods shall not be installed in the conduit with cooperative service conductors, nor can it be spliced or terminated in the meter sockets on the utility portion of the pedestal.

Grounding systems for all Electrical Service Entrances will meet electrical code requirements if 2 ground rods are installed at least 8 feet apart. (There are other variations of these grounding systems as described in IHLR 16.27 and NEC 250 Section H.)

Ground rods and grounding electrode conductors shall not be located in front of meter pedestals, wire troughs or within 2 feet of underground cable route.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 7 - Motors and Motor Regulations

All motor equipment connected to the Cooperative's system is subject to approval by the Cooperative with respect to starting characteristics and frequency of starts. The Cooperative shall be consulted before installation of motors larger than 10 hp.

Motor installations including starting devices, if necessary, shall be required to have starting characteristics which will not cause an instantaneous voltage drop to other members' service nor cause objectional lighting flicker.

Installations of motors used to drive equipment requiring a variable torque, such as compressors, reciprocating type pumps, sawmills, etc., shall be required to limit the variation of the motor current so that it will not interfere with service to other members. The Cooperative reserves the right to require the member to provide, at his own expense, equipment to control the fluctuations within limits prescribed by the Cooperative. The maximum allowable variation of motor current for each specific installation may be obtained by contacting the Cooperative.

All member-owned equipment shall be protected from excessive current which may result from overload, undervoltage, single-phase operation of three-phase motor, etc., with fuses, thermal cutouts, overload relays, or other protective devices designed to protect the individual motor. The protective equipment shall be provided by the member.

Three-Phase Motors

Because of varying conditions on the Cooperative system in different locations, it will be necessary to consult the Cooperative in each case to determine the maximum value of starting current, or less, may be started across the line. Motors with greater starting current may require member equipment to limit the starting current.

At a location where three-phase service is being used and approval has been given for specific motors or motors with starting equipment, other equipment may be installed without further approval as to starting provided that the starting, duty and frequency is no more severe than existing motors. Additional load which will increase the maximum load by 25% or more over a present authorization shall be approved by the Cooperative. This will permit the Cooperative to arrange for proper transformer capacity.

To safeguard the installation, it shall be the responsibility of the member to provide motors with protective and control equipment such as protection against low voltage, overcurrent, phase failure, short circuit, and against phase reversal where reverse operation of a three-phase motor may cause injury or damage.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 8 - Water Heating

The member shall consult the Cooperative for correct application of available rates and for assistance in determining which method of installation is desired before wiring layouts are made or equipment is purchased.

Electric water heaters may be connected to the farm, residential and small commercial rate or to the dual fuel & electric thermal storage rate.

Electric water heaters shall be installed in accordance with local and state plumbing and electric codes.

Continuous Service Water Heating

Electric water heaters may be connected to the general service meter under the residential, farm or small commercial rate in the Cooperative's service area. Monthly credits to the energy bill are available when these water heaters are permitted to be controlled during hours of peak demand for electricity. Contact the Cooperative office for details.

Water heaters may be connected to 120 volts or 240 volts service. Water heaters shall be equipped with thermostatically controlled noninductive heating elements. The maximum allowable wattage of the element is 1650 watts at 120 volts or 5500 watts at 240 volts. Water heaters having dual elements shall have them connected or interlocked to limit the connected load to the above limits.

Nonstorage, instant recovery water heaters with wattages above 5500 watts may cause service interference. Consult with the Cooperative office before installation.

Storage Type Space Heating and Cooling

Electric water heaters may be connected to the dual fuel/electric thermal storage rate. Contact the Cooperative office for installation specifications.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 9 Electric Space Heating

Electric space heating equipment may be connected to the general service meter under the residential, farm or commercial rate. The Cooperative shall be contacted prior to the installation of electric space heating to review the installation and to assure proper application of rates.

Permanently installed electric space heating designed to operate at 120 volts shall be limited to 1650 watts controlled by a single thermostat. Electric space heating designed to operate at 208 volts and above shall be limited to 6000 watts an element. Multiple elements installed in or as part of a unit exceeding 6000 watts shall be energized in stages not to exceed 6000 watts a stage and at time intervals of not less than three seconds between each stage.

Storage type space heating equipment may be installed and connected to a special off-peak service. Contact the Cooperative office for installation specifications.

Chapter 10 – Rectifying Type Controls

Speed or energy controls using rectifiers or other devices which cause wave form distortion shall be approved by the Cooperative prior to installation. Members utilizing such devices shall provide adequate filtering or isolating equipment to prevent interference with service provided by the Cooperative.

Chapter 11 – Electric Welders and Furnaces

The consent of the Cooperative shall be obtained, and any changes in the member's wiring and in the Cooperative's facilities necessary to permit welder operation under safe conditions and without interference to the service of other members shall be completed before any electric welder is connected.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 12 – Customer Generating Equipment

Standby Generating Equipment

The Cooperative shall be consulted before any generating equipment is connected to any circuits which are or may be supplied from Cooperative's service lines.

The member shall install an approved double throw switch or throwover switches that are mechanically interlocked, are of adequate current and voltage rating and are so connected that the member's generating equipment cannot energize the Cooperative's supply lines.

The double-throw or throw-over switch may be manually or automatically operated. Member-owned generating equipment shall not operate in parallel with the Cooperative's system except under specific contract with the Cooperative covering the conditions of such operation.

Parallel Generation System

A parallel generation system allows the transfer of electrical energy from the member's generator in the Cooperative's distribution system. Consult the Cooperative for the rules and requirements of this service.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

CHAPTER 13 – Mobile Homes vs. Modular Homes

Mobile Homes

A mobile home is defined as a factory-assembled structure or structures equipped with the necessary service connections and made so as to be readily movable as a unit or units on its own running gear and designed to be used as a dwelling unit without a permanent foundation. A mobile home is identified with a red metal rectangular label affixed to the rear of each full or half unit. *Permanent foundations and permanently connected water and sewer facilities do not change the definition of a mobile home or the rules governing the electric service entrance requirements.*

The member shall consult the Cooperative before such an installation is planned or started. The mobile home pedestal or pole shall be located adjacent to the mobile home (no closer than three feet) and not mounted on or in the mobile home.

The service equipment containing the disconnecting means, overcurrent protective devices and receptacles or other approved means for connecting a mobile home service, shall be located in sight of and not more than 30 feet from the exterior wall and not mounted in or on the mobile home. A minimum 100 amp service is required, however for underground service, the meter socket or pedestal must be 200 amp.

The pole or pedestal shall be installed to the prescribed depth, back-filled, and tamped to assure that the fixture remains plumb and the electric meter shall be positioned to face away from the mobile home and preferably face the driveway or road.

Oconto Electric will provide and install a pole for the service entrance if requested by the member. This will be done for a fee to the member, and that will be calculated at the current pricing structure at the time of installation.

Modular Homes

A modular home will be identified with a red plastic seal called a “Wisconsin Insignia” shaped in the outline of the state of Wisconsin. It will usually be affixed to the electrical panel, vanity base cabinet or kitchen cabinet. A modular home as defined by the Uniform Dwelling Code can have the meter pedestal affixed to the dwellings.

Single Meter Installation

The Cooperative shall own and install the service conductors and the meter.

Grouped Meter Installation

The member shall own and install the service pedestal which shall include overcurrent protection and service disconnecting means. Each service switch, breaker, or meter socket shall bear a distinctive, permanent marking clearly identifying the location to be served.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Chapter 14 – Load Management

Load Management...the intelligent use of electricity by reducing consumption when electric demand is high...and making use of it when demand is low.

Oconto Electric Cooperative offers members the opportunity to take part in load management programs and to receive rebates for installing electric water heaters, space heating equipment, central heating/cooling equipment, electric plenum heaters and electric boilers. The programs associated with these products are outlined on the following pages.

For more specific details please contact Oconto Electric Cooperative.

All programs are subject to change at the discretion of the Board of Directors and Management.

Water Heater Program

Oconto Electric Cooperative's most popular load management program allows the cooperative to shut off electric water heaters during periods of high electric demand. By having an energy efficient Marathon water heater, the member gets the best value for his/her money.

Rebates on certain models of Marathon water heaters are available from Oconto Electric Cooperative and/or Focus on Energy. Call OEC for current pricing.

Program Information:

- Water heater will be delivered at no charge.
- Installation of the heater is the responsibility of the member.
- Load management switch will be installed by OEC technician.
- Switch must remain on the water heater for a minimum of 5 years.
- Member will receive monthly \$5 credit on electric bill provided usage is over 400 kilowatt-hours in that month.
- OEC reserves the right to periodically inspect the load management switch.

There is a \$20 sign-up bonus if a member wishes to place his/her existing electric water heater on the load management program.

Geothermal Heat Pump Program-Dual Fuel

Oconto Electric Cooperative members who install a Geothermal Heat Pump (GHP) with an automatic, fossil fuel or thermal storage heat source are eligible to utilize the cooperative's dual fuel rate for the GHP.

OEC will install a load management switch on the GHP which allows the coop to shut off the heat pump during times of high electric demand. It is during those

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

periods that the backup fuel source must begin to operate automatically. (Wood heat is NOT considered an automatic backup.)

A dual fuel metering package must be installed by members' electrical contractor. An appointment must be scheduled for an OEC technician to install the dual fuel meter and complete the final inspection of the geothermal installation.

Air Source Heat Pump Program-Dual Fuel

An Air Source Heat Pump (ASHP) is another extremely efficient way for a person to heat and cool their home. When heating, an ASHP takes heat from outside air, condenses it, and distributes it throughout the home. These units are ideal when used in conjunction with a plenum heater (see below). When the temperature outside is too low for the heat pump to provide enough heat, the plenum heater adds enough heat to meet the home's heating requirements.

For cooling the ASHP takes the heat and humidity out of home and discharges it outside, the way central air conditioning does. An OEC technician will install a switch on the heat pump which will allow the cooperative to shut off the heat pump during times of high electric demand. When the cooperative controls heating, the heat pump will be shut off during the high demand period and the fossil fuel must automatically take over. For cooling, the unit will be allowed to cycle on and off at approximate 20-30 minute intervals so the unit is cooling for half of the time.

An Air Source Heat Pump will be eligible for the dual fuel rate if it is used for heating in conjunction with an automatic, fossil fuel or thermal storage backup. A special metering package is required and can be purchased through Oconto Electric.

Plenum Heater

Plenum heaters are installed into the supply air plenum of a forced-air furnace. Electricity is used to heat the plenum heater coils and the warm air is distributed by the furnace fan. The existing furnace may be natural gas, propane or fuel oil. Electricity used for the plenum heater is eligible for the Dual Fuel and Electric Thermal Storage rate.

A special metering package is required and can be purchased through Oconto Electric.

Electric Thermal Storage Program

Electric Thermal Storage (ETS) heating is an option which allows the member to utilize the Dual Fuel and Electric Thermal Storage rate. Thermal storage may in the form of individual room units, a centrally ducted, forced air furnace or hydronic in-floor heat. During off-peak times, heat is stored in a high-density brick core. This stored heat is delivered to the home during on-peak times when

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

OEC controls electric heating load. A consistent room temperature can be maintained for up to 16 hours.

All types of ETS units need a metering package which is purchased from OEC to be eligible for the dual fuel rate.

Electric Boiler Program

Electric boilers generate heat that is distributed via radiant floor systems or hydronic baseboards. An automatic fossil fuel or thermal storage backup is required to be eligible for the dual fuel rate. (Wood heat is NOT considered an automatic backup.) When eligibility requirements are met, the electric boiler is metered on the dual fuel rate.


A special metering package is required and can be purchased through Oconto Electric.

Central Air Conditioning Program

OEC would like to be able to manage all central air conditioning load. A technician will install a switch on the unit which will allow the cooperative to shut the AC off during times of high electric demand. When the cooperative controls cooling, the unit will be allowed to cycle on and off at approximate 20-30 minute intervals. Members will receive an \$8 monthly credit on their electric bills for the months of June, July, August and September consumption.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

Load Management Receiver Wiring Guide



Oconto Electric Cooperative
Oconto Falls, WI 54154
1-800-472-8410

Load Management
Receiver Wiring Guide

2-9-2005

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

APPROVED EQUIPMENT LIST

100-200 Ampere, Single-phase, Overhead

Socket must be UL listed, 100 amp minimum, ringless style, with a manual bypass horn

200 Ampere, Single-phase meter pedestal catalog numbers

Manufacturer	Single Position	Duplex Position	Extension
Siemens (L & G)	UAP317-PPW1		5007718
Anchor	Mp-5S-204B-WI		Mp-5S-Es
Murray	RP118SW		UXO78B
Milbank	U3358-O-KK	U1783-O-KK	K4695
Milbank w/breaker	NU8980-0-KK		
Square D (Durham)	UHTRP2423-63-SQD		
Midwest	R2EMSSP6		EK129CW
Milbank	U4329-O (Joint use pedestal for Telephone, CATV & Electric)		

320 Ampere, Single-phase (Residential use by Cooperative approval only)

Manufacturer	Single Position	Duplex Position	Extension
Milbank	U1748-0-WI		S1848
Cutler Hammer	1009018CH		1009023

Current Transformer Enclosures for Overhead & Underground Services Above 200 Amperes

Rating	Mfg.	Overhead Service	Underground Service	Underground Erickson
400 amp/3 wire	RJB	WPS-403	WPS-403UG	1182-1 WPS
400 amp/4 wire	RJB	WPS-404	WPS-404UG	1182-2 WPS
600 amp/3 wire	RJB	WPS-603	WPS-603UG	1076-1 WPS-LE
600 amp/4 wire	RJB	WPS-604	WPS-604UG	1076-2 WPS-LE
800 amp/3 wire	RJB	WPS-803	WPS-803UG	1076-1 WPS-LE
800 amp/4 wire	RJB	WPS-804	WPS-804UG	1076-2 WPS-LE

200 Ampere, 3-phase meter sockets (7 Jaw 120/208, 277/480 Volt)

Manufacturer	Type of Service	Catalog Number	Extension Catalog Number
Anchor	Overhead	U42572-HO/HLO	
Murray	Overhead	RH-173-GR	
Siemens (Landis & Gyr)	Overhead	40007	
Siemens (Landis & Gyr)	Underground	40407P-9WI	
Milbank	Overhead	U9700-XL	
Milbank	Underground	U9107-O	S3488

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

APPROVED EQUIPMENT LIST

Single-phase, Transformer Rated Meter Sockets

<u>Manufacturer</u>	<u>5 Terminal</u>	<u>6 Terminal</u>
Anchor	URS 1004-B-HO	URS 1004-B-HO
Extra terminal	(1)8855-1 required	(2)8855-1 required
Milbank	U7487-RL-KK-TG	U7487-RL-KK-TG
Extra terminal	(1)5T24R required	(2)5T24R required

****Extra terminal shall be bolted to base. No push-in terminals allowed.**

Three-phase transformer rated sockets, 13 terminal

<u>Manufacturer</u>	<u>Single position</u>
Anchor	TSS13-HO-SRI
Meter Devices	3040A-13
Milbank	UC7449-XL
RJB	MS-2034-13
Erickson	W-340
Siemens (L & G)	9837-8503

Mobile Home Meter Pedestals

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Post Extension</u>	<u>Stabilizer Foot</u>
Anchor	PRMB2 Series	UPX	UPS
Midwest	M or R 281C1P6H	EK129	FBEM9
Milbank	U5136		K5415

*Milbank catalog number NU8980-0-KK is not acceptable as an approved mobile home or free standing pedestal.

Pole Top Transfer Switches

<u>Manufacturer</u>	<u>Size</u>	<u>Catalog Number</u>
Ronk	200 Amp/Single-Phase	9205
Ronk	400 Amp/Single-Phase	9406
Ronk	200 Amp/Three-Phase	9805
Ronk	400 Amp/Three-Phase	9806

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS
OVERHEAD SERVICE ON BUILDING
200 Amps or less**

1. Cooperative shall furnish and install conductors to terminate at service mast.
2. Cooperative shall furnish and install connectors to connect the Cooperative's conductors to the Member's conductors.
3. Member shall furnish and install a 100 Amp or 200 Amp meter socket, as required. (See "Approved Equipment List" page 27)
4. Member shall furnish and supply mast, weatherhead, roof flashing, straps, and conductors. The mast shall be minimum 2" rigid steel conduit or steel Intermediate Metal Conduit (IMC).
5. Member shall furnish and install load conductors between the meter socket and the service disconnecting means. Service entrance conductors shall not extend over 8 feet into a building unless overcurrent protection is provided at the outer end.
6. **Member shall furnish and install two 5/8" X 8' copperclad steel ground rods and approved clamps.** Ground rods and grounding conductors shall not be installed in front of the meter pedestal.
7. **The grounding electrode conductor from the ground rods shall not be spliced or terminated in the meter socket.** The grounding electrode conductor shall be accessible outside of and adjacent to the meter socket for connection of telephone, cable TV, or utility grounding conductors. Top of ground rods should be at least 12" below grade level. **Ground wire shall be minimum 4 AWG copper wire.**
8. Member shall furnish and install guy wire and roof attachments as required. (See Guying Requirements for Mast Type Service Entrances below.)
9. Wiring shall be installed in compliance with state electrical code and any local requirements.

GUYING REQUIREMENTS FOR MAST TYPE SERVICE ENTRANCES

It is strongly recommended that all mast type services be supported by a guy wire, regardless of mast height. However, if the following minimum criteria exist, support guying may be omitted:


	For 100 amp service			For 200 amp service		
Conduit	2"	2 1/2"	3"	2"	2 1/2"	3"
Service drop						
Length up to 40'	8'	8'	8'	40'	7'	8'
	50'	7'	8'	50'	6'	7'6"
	60'	4'6"	8'	60'	3'6"	5'
	70'	3'6"	7'	70'	2'6"	5'
	80'	3'	5'6"	80'	2'	4'
	90'	2'6"	4'6"	90'	*	3'
	100'	2'	4'	100'	*	2'6"

* Mast type entrances will not meet code requirements

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

OVERHEAD SERVICE ON BUILDING 200 Amps or less

+ Maximum height above roof to meet strength requirements. See NEC to determine minimum clearance requirements for service wires.




**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

**OVERHEAD SERVICE
200 amp or less**

1. Cooperative shall furnish and install 30-foot pole.
2. Cooperative shall furnish and install conductors to terminate at meter pole.
3. Cooperative shall furnish and install connectors to connect the Cooperative's conductors to the Member's conductors.
4. Member shall furnish and install a 100 Amp or 200 Amp meter socket, as required. (See "Approved Equipment List")
5. Member shall furnish and install separate supply side and load side conduits complete with weatherhead, straps, and conductors. **Service entrance (SE) cable shall not be used on pole.**
6. Member shall furnish and install a weatherproof disconnecting means. The disconnecting means shall be located on the load side of the meter socket.
7. **Member shall furnish and install two 5/8" X 8' copperclad steel ground rods with approved clamps.** Top of rods should be at least 12" below grade level.
8. Wiring shall be installed in compliance with state electrical code and any local requirements.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

**OVERHEAD SERVICE
200 Amps or less**



OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS


Underground Service 200 Amp Meter Pedestal

1. The Cooperative shall furnish and install the line conductors. Where the Cooperative's wires will be covered by concrete or blacktop, the member shall provide conduit to extend at least 3 feet beyond the edge of the concrete or blacktop.
2. Member shall furnish and install a 200-amp meter pedestal approved by the Cooperative.
3. Member shall furnish and install load conductors between the meter pedestal and the service disconnecting means. Service entrance conductors shall not extend over 8 feet into a building unless overcurrent protection is provided at the outer end.
4. Member shall furnish and install two 5/8" copperclad steel ground rods and approved clamps. Ground rods and grounding conductors shall not be installed in front of the meter pedestal or within 2 feet of the underground cable route.
5. The grounding electrode conductor from the ground rods shall not be spliced or terminated in the meter socket or utility portion of the pedestal. The grounding electrode conductor shall be accessible outside the pedestal for connection of telephone, cable TV, or other utility-grounding conductors. The top of the ground rods should be at least 12" below grade level. Ground wire shall be minimum 4 AWG copper wire.
6. Adequate space shall be provided for removal of the meter pedestal cover when concrete or blacktop covers the area in front of the meter pedestal.
7. Member shall furnish and install an extension for the pedestal, if required, to provide a minimum of 18" of pedestal below final grade level.
8. Wiring shall be installed in compliance with state electrical code and any local requirements.
9. No meter pedestal shall be installed under any windows.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Underground Service 200 Amp Meter Pedestal

NO CONDUIT OR
CONDUCTORS TO
BE INSTALLED
ABOVE OR BESIDE
THE METER



**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

Underground Service


200 Amp Meter Pedestal (with Main Breaker)

(The unit shown in the sketch is a Milbank # NU8980-0-KK-LP)

1. The Cooperative shall furnish and install the line conductors. Where the Cooperative's wires will be covered by concrete or blacktop, the member shall provide conduit to extend at least 3 feet beyond the edge of the concrete or blacktop.
2. Member shall furnish and install a 200 amp meter pedestal with main breaker, approved by the Cooperative.
3. Member shall furnish and install load conductors between the meter pedestal and the breaker panel.
4. Member shall furnish and install two 5/8" copperclad steel ground rods and approved clamps. Ground rods and grounding conductors shall not be installed in front of the meter pedestal or within 2 feet of the underground cable route.
5. The grounding electrode conductor from the ground rods shall not be spliced or terminated in the meter socket or utility portion of the pedestal. The top of the ground rods should be at least 12" below grade level. Ground wire shall be minimum 4 AWG copper wire.
6. Adequate space shall be provided for removal of the meter pedestal cover when concrete or blacktop covers the area in front of the meter pedestal.
7. Member shall furnish and install an extension for the pedestal, if required, to provide a minimum of 18" of pedestal below final grade level.

Wiring shall be installed in compliance with state electrical code and any local requirements.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS



OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS


MOBILE HOME OVERHEAD SERVICE

1. Cooperative shall furnish and install 30-foot pole.
2. Cooperative shall furnish and install conductors to terminate at meter pole.
3. Cooperative shall furnish and install connectors to connect the Cooperative's conductors to the Member's conductors.
4. Member shall furnish and install a 100 Amp or 200 Amp meter socket, as required. (See "Approved Equipment List")
5. Member shall furnish and install conduit complete with weatherhead, straps, and conductors. **Service entrance (SE) cable shall not be used on pole.**
6. Member shall furnish and install a weatherproof disconnecting means. The disconnecting means shall be located on the load side of the meter socket.

The service equipment or a disconnecting means suitable for service equipment shall be located insight from and not more than 30 feet from the exterior wall of the mobile home it serves.

- 7. Member shall furnish and install two 5/8" X 8' copperclad steel ground rods with approved clamps. Top of rods should be at least 12" below grade level.**
8. Member shall furnish and install the feeder to the mobile home. The feeder shall consist of 4 insulated conductors of which one shall be an insulated copper equipment-grounding conductor. The equipment-grounding conductor shall be minimum 6 AWG insulated copper.
9. Wiring shall be installed in compliance with state electrical code and any local requirements.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS
MOBILE HOME OVERHEAD SERVICE**



OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

MOBILE HOME UNDERGROUND SERVICE 200 amps or less

1. The Cooperative shall furnish and install the line conductors. Where the Cooperative's wires will be covered by concrete or blacktop, the member shall provide conduit to extend at least 3 feet beyond the edge of the concrete or blacktop.
2. Member shall furnish and install a 200 amp meter pedestal (*) approved by the Cooperative. (See "Approved Equipment List")
3. Member shall furnish and install treated posts and backboard or other support structure approved by the Cooperative. Treated wood posts of 6" X 6" nominal dimension and treated plywood of 3/4" minimum thickness will meet minimum requirements. The mobile home service equipment shall be located adjacent to the mobile home, a three-foot separation and not mounted in or on the mobile home.
4. Member shall furnish and install a weatherproof disconnecting means and all connecting conduits and conductors. (*)
5. Member shall furnish and install **two 5/8" X 8' copperclad steel ground rods and approved clamps**. Ground rods and grounding conductors shall not be installed in front of the meter pedestal or within 2 feet of the underground cable route.
6. The grounding electrode conductor from the ground rods shall not be spliced or terminated in the meter socket or utility portion of the pedestal. The grounding electrode conductor shall be accessible outside the pedestal for connection of telephone, cable TV, or other utility-grounding conductors. Top of ground rods should be at least 12" below grade level. **Ground wire shall be minimum 4 AWG copper wire.**
7. Adequate space shall be provided for removal of the meter pedestal cover when concrete or blacktop covers the area in front of the meter pedestal.
8. Member shall furnish and install an extension for the pedestal, if required, to provide a minimum of 18" of pedestal below final grade level.
9. Member shall furnish and install the feeder to the mobile home. **The feeder shall consist of 4 insulated conductors of which one shall be an insulated copper equipment-grounding conductor. The equipment-grounding conductor shall be minimum 6 AWG insulated copper.**

The service equipment or a disconnecting means suitable for service equipment shall be located in sight from and not more than 30 feet from the exterior wall of the mobile home it serves.


10. Wiring shall be installed in compliance with state electrical code and any local requirements.

* It is also acceptable to use a meter pedestal with the breakers installed in the pedestal. See "Approved Equipment List".

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

MOBILE HOME UNDERGROUND SERVICE 200 amps or less

NO CONDUIT OR
CONDUCTORS TO
BE INSTALLED
ABOVE OR BESIDE
THE METER



OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS


Mobile Home Underground Service – Free Standing Pedestal 200 Amps or Less

1. The Cooperative shall furnish and install the line conductors. Where the Cooperative's wires will be covered by concrete or blacktop, the member shall provide conduit to extend at least 3 feet beyond the edge of the concrete or blacktop.
2. Member shall furnish and install a 200 amp meter pedestal (*) approved by the Cooperative. (See "Approved Equipment List") The mobile home service equipment shall be located adjacent to the mobile home, a three foot separation and not mounted in or on the mobile home.
3. Member shall furnish and install a stabilizer foot approved by the Cooperative.
4. Member shall furnish and install the circuit breaker and all connecting conduits and conductors. (*)
5. Member shall furnish and install **two 5/8" x 8' copperclad steel ground rods and approved clamps**. Ground rods and grounding conductors shall not be installed in front of the meter pedestal or within 2 feet of the underground cable route.
6. The grounding electrode conductor from the ground rods shall not be spliced or terminated in the meter socket or utility portion of the pedestal. The grounding electrode conductor shall be accessible outside the pedestal for connection of telephone, cable TV, or other utility-grounding conductors. Top of ground rods should be at least 12" below grade level. **Ground wire shall be minimum 4 AWG copper wire.**
7. Adequate space shall be provided for removal of the meter pedestal cover when concrete or blacktop covers the area in front of the meter pedestal.
8. Member shall furnish and install the feeder to the mobile home. **The feeder shall consist of 4 insulated conductors of which one shall be an insulated copper equipment grounding conductor. The equipment grounding conductor shall be minimum 6 AWG insulated copper.**


Wiring shall be installed in compliance with state electrical code and any local requirements.

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

Mobile Home Underground Service – Free Standing Pedestal 200 Amps or Less



(UNIT SHOWN IS THE MILBANK # U3136-0-200-KK)




**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

**400 AMP OVERHEAD SERVICE POLE TOP DISCONNECT
CURRENT TRANSFORMER METERING**

1. Cooperative shall furnish and install 30-foot pole.
2. Cooperative shall furnish and install conductors to terminate outside of pole top disconnect.
3. Cooperative shall burnish and install current transformer and mounting bracket.
4. Cooperative shall furnish and install metering conductors.
5. Member shall furnish and install pole top disconnect. Disconnect shall be located a minimum of 15" from top of pole to top of disconnect enclosure. Pole top disconnect shall have double throw capability for connecting standby generator.
6. Member shall furnish and install a 100-amp meter socket with 5th terminal in the 9 o'clock position. This terminal shall be the bolt-in type. No push-in terminals allowed. (See "Approved Equipment List")
7. Member shall furnish and install a 1" conduit complete with weatherhead and straps, as required, for metering conductors. Weatherhead to be 12 inches below item #3 location.
8. Member shall furnish and install insulated conductors terminated in the pole top disconnect and extending 2 feet outside of disconnect enclosure.
9. Member shall bond disconnect handle to ground wire.
- 10. Member shall furnish and install two 5/8" X 8' copperclad steel ground rods with approved clamps. Top of rods should be at least 12" below grade level. Ground wire shall be minimum 2 AWG copper wire.**
11. Wiring shall be installed in compliance with state electrical code and any local requirements.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS
400 AMP OVERHEAD SERVICE POLE TOP DISCONNECT
CURRENT TRANSFORMER METERING**



OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

400 AMP SINGLE PHASE UNDERGROUND SERVICE

1. Cooperative shall furnish and install current transformers.
2. Cooperative shall furnish and install metering conductors.
3. Cooperative shall furnish and install underground line conductors.
4. Member shall furnish and install treated posts and backboard or other support structure approved by the Cooperative. Treated wood posts of 6" X 6" nominal dimension and treated plywood of ¾" minimum thickness will meet minimum requirements.
5. Member shall furnish and install a Cooperative approved current transformer enclosure and all connecting conduit. (See "Approved Equipment List")
6. Member shall furnish and install 3" minimum rigid steel or schedule 80 PVC to extend a minimum of 18" below finished grade.
7. Member shall furnish and install a 100 amp meter socket with 2 5th lug terminal kits, one in the 3 o'clock position and one in the 9 o'clock position and a minimum 1" connecting conduit. These terminals shall be the bolt-in type. No push-in terminals allowed.
8. Member shall furnish and install double throw switch (required, if standby generator is used) and service equipment, as required.
9. Member shall furnish and install load conductors and connectors.
10. Member shall furnish and install grounding conductor and conduit.
11. Member shall furnish and install **two 5/8" X 8' copperclad steel ground rods with approved clamps**. Top of rods should be at least 12" below grade level. Ground wire shall be minimum 2 AWG copper wire.
12. Wiring shall be installed in compliance with state electrical code and any local requirements.
13. Member shall furnish and install the ground wire jumper conductor from the neutral buss bar to the enclosure with approved bonding clamps and a minimum of 2/O copper-stranded conductor.

**OCONTO ELECTRIC COOPERATIVE
WIRING SPECIFICATIONS AND RECOMMENDATIONS**

**400 AMP & ABOVE
THREE-PHASE UNDERGROUND SERVICE**

1. Cooperative shall furnish and install current transformers.
2. Cooperative shall furnish and install metering conductors.
3. Cooperative shall furnish and install underground line conductors.
4. Member shall furnish and install a Cooperative approved current transformer enclosure and all connecting conduit. (See "Approved Equipment List")
5. Member shall furnish and install rigid steel or schedule 80 PVC conduit specified by Cooperative and this conduit or conduits are to extend a minimum of 18" below finished grade.
6. Member shall furnish and install load conductors and connectors.
7. Member shall furnish and install grounding conductor and conduit.
8. Member shall furnish and install **two 5/8" X 8' copperclad steel ground rods with approved clamps**. Top of rods should be at least 12" below grade level. Ground wire shall be minimum 2 AWG copper wire.
9. Member shall furnish and install the ground wire jumper conductor from the neutral buss bar to the enclosure with approved bonding clamps and a minimum of 2/O copper-stranded conductor.
10. Members shall furnish and install the 13-lug meter socket with test switches per the "Approved Equipment List". (Example, Milbank # UC 7449-XL)

OCONTO ELECTRIC COOPERATIVE WIRING SPECIFICATIONS AND RECOMMENDATIONS

400 AMP & ABOVE THREE-PHASE UNDERGROUND SERVICE

